

CCFD Fire Station 4 Lake Road

Clac_fir08A

Clackamas Co Fire Dist #1

Building Type		County	
Fire - RFPD		Clackamas	
Street			
6600 Se Lake Rd			
City	State	Zip	
Milwaukie	OR	97222	
Latitude		Longitude	
45.42552		122.59532	
Tracking Code		Inspection Date	
New Building		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	2.8	0	0	0	5.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


CCFD Fire Station 4 Lake Road

Final RVS Score

Final Type	Final Score
RM1	5.6

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		2000	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
10900	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions