

CCFD Fire Station 1 Town Center

Clackamas Co Fire Dist #1

Clac_fir09A

Building Type Fire - RFPD	County Clackamas	
Street 11300 SE Fuller Rd		
City Milwaukie	State OR	Zip 97222
Latitude 45.4406	Longitude 122.5819	
Tracking Code Hasenberg 02	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	0	0	0	-0.4	0	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

CCFD Fire Station 1 Town Center

Final RVS Score

Final Type	Final Score
PC1	2.2

FEMA-154 Collapse Potential

Low (<1%)

CCFD Fire Station 1 Town Center

Clac_fir09A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1983	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
9690	2	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site