

# Boring Fire Protection

Boring RFPD

Clac\_fir22A

Building Type Fire - RFPD	County Clackamas	
Street 28655 Se Hwy 212		
City Boring	State OR	Zip 97009
Latitude 45.43287	Longitude 122.36825	
Tracking Code Hasenberg 02	Inspection Date 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	0	0	0	0	0	0	2.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Boring Fire Protection

## Final RVS Score


Final Type	Final Score
PC1	2.6

## FEMA-154 Collapse Potential

Low (<1%)

# Boring Fire Protection

Clac\_fir22A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1969	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
19800	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site