

# Lake Oswego Fire Department

City of Lake Oswego

Clac\_fir23A

Building Type Fire - City	County Clackamas									
Street 4555 Jean Rd										
City Lake Oswego	State OR	Zip 97035								
Latitude 45.39727	Longitude 122.72369									
Tracking Code Hasenberg 02	Inspection Date 9/15/2006									
Seismicity Zone: High										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	-0.4	0	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lake Oswego Fire Department

**Final RVS Score**

Final Type RM1	Final Score 2.4
-------------------	--------------------

**FEMA-154 Collapse Potential**

Low (<1%)
-----------



# Lake Oswego Fire Department

Clac\_fir23A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built		
		1970			
Total Area (square ft)	Number of Stories	Basement	Pounding Potential		
5650	1	No	No		
Plan Irregularities		Vertical Irregularities			
Falling Hazards		Poor Conditions			
	S General Site		S General Site		S General Site