

CCFD Fire Station 12 Logan

Clackamas Co Fire Dist #1

Clac_fir24A

Building Type Fire - RFPD	County Clackamas	
Street 18081 S Harding Rd		
City Oregon City	State OR	Zip 97045
Latitude 45.34411	Longitude 122.42325	
Tracking Code Hasenberg 02	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	2.4	-0.4	0	0	5.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

CCFD Fire Station 12 Logan

Final RVS Score

Final Type	Final Score
W2	5.8

FEMA-154 Collapse Potential

Low (<1%)

CCFD Fire Station 12 Logan

Clac_fir24A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1985	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
7350	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries