

CCFD Fire Station 2 Milwaukie

Clackamas Co Fire Dist #1

Clac_fir26A

Building Type Fire - RFPD	County Clackamas	
Street 3200 Se Harrison		
City Milwaukie	State OR	Zip 97222
Latitude 45.44617	Longitude 122.62866	
Tracking Code Hasenberg 02	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S2	3	0	0	0	0	-0.4	0	0	2.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

CCFD Fire Station 2 Milwaukie

Final RVS Score

Final Type	Final Score
S2	2.6

FEMA-154 Collapse Potential

Low (<1%)

CCFD Fire Station 2 Milwaukie

Clac_fir26A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1992	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
34900	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries