

CCFD Fire Station 14 Highland

Clackamas Co Fire Dist #1

Clac_fir28A

Building Type Fire - RFPD	County Clackamas									
Street 22295 S Lower Highland Rd										
City Beaver Creek	State OR	Zip 97004								
Latitude 45.24847	Longitude 122.4087									
Tracking Code Hasenberg 02	Inspection Date 9/15/2006									
Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	0	0	0	-0.8	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

CCFD Fire Station 14 Highland

Final RVS Score

Final Type RM1	Final Score 2.8
-------------------	--------------------

FEMA-154 Collapse Potential

Low (<1%)



CCFD Fire Station 14 Highland

Clac_fir28A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1960	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
1850	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site		