

CCFD Fire Station 9 Holcomb

Clackamas Co Fire Dist #1

Clac_fir29A

Building Type Fire - RFPD	County Clackamas	
Street 300 Longview Wy		
City Oregon City	State OR	Zip 97045
Latitude 45.37302	Longitude 122.5684	
Tracking Code Hasenberg 02	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	0	0	0	0	4.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

CCFD Fire Station 9 Holcomb

Final RVS Score

Final Type	Final Score
W1	4.4

FEMA-154 Collapse Potential

Low (<1%)

CCFD Fire Station 9 Holcomb

Clac_fir29A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1970	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
3450	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries