

# Hoodland RFPD 74

Clac\_fir30A

Hoodland RFPD

Building Type Fire - RFPD	County Clackamas	
Street 87600 E Government Camp Lp		
City Government Camp	State OR	Zip 97028
Latitude 45.30474	Longitude 121.76376	
Tracking Code Hasenberg 02	Inspection Date 9/15/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	1.6	0	-0.6	0	6.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hoodland RFPD 74

## Final RVS Score

Final Type	Final Score
W1	6.2

## FEMA-154 Collapse Potential

Low (<1%)

# Hoodland RFPD 74

Clac\_fir30A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1980	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
4800	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries