

Colton RFPD

Building Type Fire - RFPD	County Clackamas	
Street 24479 S Elwood Rd		
City Colton	State OR	Zip 97017
Latitude 45.20516	Longitude 122.36259	
Tracking Code New Building	Inspection Date 9/15/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	0	0	0	0	0	0	3.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Colton RFPD

Final RVS Score

Final Type	Final Score
S3	3.8

FEMA-154 Collapse Potential

Low (<1%)

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1995	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
1800	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site		

