

Sandy FFPD 72

Sandy FFPD

Clac_fir42A

Building Type Fire - RFPD	County Clackamas	
Street 13120 SE Ten Eyck Rd		
City Sandy	State OR	Zip 97055
Latitude 45.42941	Longitude 122.23987	
Tracking Code Hasenberg 02	Inspection Date 9/15/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	0	-0.8	0	0	4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sandy FFPD 72

Final RVS Score

Final Type	Final Score
W2	4

FEMA-154 Collapse Potential

Low (<1%)

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1972	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
2100	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	

