

# Gladstone Fire

City of Gladstone

Clac\_fir44A

Building Type	County		
Fire - City	Clackamas		
Street			
555 Portland Ave			
City	State	Zip	
Gladstone	OR	97027	
Latitude	Longitude		
45.38069	122.59439		
Tracking Code	Inspection Date		
Hasenberg 02	9/15/2006		



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Gladstone Fire

## Final RVS Score

Final Type

Final Score

RM1

2.8

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1970	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
4000	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions



S General Site