

Boring Fire District 59

Boring RFPD

Clac_fir47A

Building Type Fire - RFPD	County Clackamas	
Street 3220 Judd Rd		
City Eagle Creek	State OR	Zip 97022
Latitude 45.36841	Longitude 122.33133	
Tracking Code New Building	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	2.4	0	0	0	6.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Boring Fire District 59

Final RVS Score

Final Type	Final Score
W1	6.8

FEMA-154 Collapse Potential

Low (<1%)

Boring Fire District 59

Clac_fir47A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1999	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
6200	1	No	No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S General Site	S General Site	S General Site	