

# Clackamas County Sheriff's Office

Clackamas County

Clac\_pol03A

Building Type		County	
Police - County		Clackamas	
Street			
2223 Kaen Rd			
City		State	Zip
Oregon City		OR	97045
Latitude		Longitude	
45.33167		122.59964	
Tracking Code		Inspection Date	
Hasenberg 02		9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	-0.4	0	0	3.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clackamas County Sheriff's Office

## Final RVS Score

Final Type

Final Score

W2

3.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1965	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
6900	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions



S General Site

S General Site

S General Site



S General Site