

Clackamas County Sheriffs Office

Clackamas County

Clac_pol04A

Building Type		County	
Police - County		Clackamas	
Street			
12800 Se 82nd Ave			
City	State	Zip	
Clackamas	OR	97015	
Latitude		Longitude	
45.43101		122.57853	
Tracking Code		Inspection Date	
New Building		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	-0.4	0	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clackamas County Sheriffs Office

Final RVS Score

Final Type

Final Score

RM1

2.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1995	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
11800	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions



S General Site



S General Site



S General Site