

Oregon City Police Department

City of Oregon City

Clac_pol11A

Building Type Police - City	County Clackamas	
Street 320 Warner Milne Rd		
City Oregon City	State OR	Zip 97045
Latitude 45.33613	Longitude 122.5942	
Tracking Code Hasenberg 02	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	-0.4	0	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Oregon City Police Department

Final RVS Score

Final Type	Final Score
RM1	2.4

FEMA-154 Collapse Potential

Low (<1%)

Oregon City Police Department

Clac_pol11A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
<input type="text"/>	<input type="text"/>	<input type="text" value="1965"/>	<input type="text"/>
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
<input type="text" value="12600"/>	<input type="text" value="1"/>	<input type="text" value="No"/>	<input type="text" value="No"/>
Plan Irregularities		Vertical Irregularities	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
Falling Hazards		Poor Conditions	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
			
S	General Site	S	General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries