

Bryant Elementary School

Lake Oswego SD 7J

Clac_sch03A

Building Type School	County Clackamas	
Street 4750 Jean Rd		
City Lake Oswego	State OR	Zip 97035
Latitude 45.3961	Longitude 122.7274	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Bryant Elementary School

Final RVS Score

Final Type	Final Score
W2	0.9

FEMA-154 Collapse Potential

High (>10%)

Bryant Elementary School

Clac_sch03A

Enrollment 291	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built
Total Area (square ft) 50135	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries