

Forest Hills Elementary School

Lake Oswego SD 7J

Clac_sch04A

Building Type	County	
School	Clackamas	
Street		
1133 Andrews Rd		
City	State	Zip
Lake Oswego	OR	97034
Latitude	Longitude	
45.42603	122.67681	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Forest Hills Elementary School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)

Forest Hills Elementary School

Clac_sch04A

Enrollment 400	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built
Total Area (square ft) 50567	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site	S	General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries