

Westridge Elementary School

Lake Oswego SD 7J

Clac_sch09A

Building Type	County	
School	Clackamas	
Street		
3400 Royce Way		
City	State	Zip
Lake Oswego	OR	97034
Latitude	Longitude	
45.39508	122.71194	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	0	0	3.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Westridge Elementary School

Final RVS Score

Final Type	Final Score
W2	3.7

FEMA-154 Collapse Potential

Low (<1%)

Westridge Elementary School

Clac_sch09A

Enrollment 328	Year Built (Field Verified) 1981	Year Built (Alt. Source) 1981	Est. Decade Built
Total Area (square ft) 46144	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	