

Bilquist Elementary School

North Clackamas SD 12

Clac_sch15A

| | | |
|-------------------------------|-------------------------------|--------------|
| Building Type School | County Clackamas | |
| Street 15708 Se Webster Rd | | |
| City Milwaukie | State OR | Zip 97267 |
| Latitude 45.40943 | Longitude 122.5889 | |
| Tracking Code RVS in 2006 | Inspection Date 12/22/2006 | |



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | RM1 | 2.8 | -1 | 0 | 0 | 0 | -0.4 | 0 | 0 | 1.4 |
| Secondary | W2 | 3.8 | -2 | 0 | 0 | 0 | -0.4 | 0 | 0 | 1.4 |
| Tertiary | S1 | 2.8 | -1 | 0 | 0 | 0 | -0.4 | 0 | 0 | 1.4 |


Bilquist Elementary School

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| RM1 | 1.4 |

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Bilquist Elementary School

Clac_sch15A

| | | | |
|---|-------------------------------------|---|---------------------------|
| Enrollment 497 | Year Built (Field Verified) 1960 | Year Built (Alt. Source) 1960 | Est. Decade Built 1960 |
| Total Area (square ft) 49581 | Number of Stories 1 | Basement | Pounding Potential No |
| Plan Irregularities | | Vertical Irregularities | |
| Reentrant Corners: Other | | Steps in Elevation View: 2 to 3 Changes | |
| Torsion: Eccentric Stiffness | | None | |
| None | | None | |
| Falling Hazards | | Poor Conditions | |
| Other: Ornamental Hazard Over Exit | | None | |
| Other: Brick Veneer | | None | |
| None | | None | |
|  | |  | |
| W Vertical Irregularity Primary | | W Falling Hazard | |
|  | | S Plan Irregularity Secondary rex putnam-like const | |
|  | | E Secondary Structural Type | |
|  | | S General Site 2001 gym | |
|  | | S Primary Structural Type | |



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries