

Boring Middle School - Old Gym

Oregon Trail SD 46

Clac_sch34A

Building Type School	County Clackamas	
Street 27801 Se Dee St		
City Boring	State OR	Zip 97009
Latitude 45.43218	Longitude 122.37727	
Tracking Code Previous FEMA-154 Report	Inspection Date 9/15/2006	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5						
Secondary										
Tertiary										



Boring Middle School - Old Gym

Final RVS Score

Final Type RM1	Final Score 1.3
-------------------	--------------------

FEMA-154 Collapse Potential

Moderate (>1%)

Boring Middle School - Old Gym

Clac_sch34A

Enrollment 404	Year Built (Field Verified) 1948	Year Built (Alt. Source) 1948	Est. Decade Built
Total Area (square ft) 9500	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
S General Site	S General Site	S General Site	
			
S General Site	S General Site	S General Site	
			
S General Site	S General Site	S General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Boring Middle School

Clac_sch34A



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site

Boring Middle School - Main

Oregon Trail SD 46

Clac_sch34B

Building Type School	County Clackamas	
Street 27801 Se Dee St		
City Boring	State OR	Zip 97009
Latitude 45.43218	Longitude 122.37727	
Tracking Code Previous FEMA-154 Report	Inspection Date 9/15/2006	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5						
Secondary										
Tertiary										

Boring Middle School - Main	
Final RVS Score	
Final Type	Final Score
C2	1.3

FEMA-154 Collapse Potential	
Moderate (>1%)	

Boring Middle School - Main

Clac_sch34B

Enrollment 404	Year Built (Field Verified) 1948	Year Built (Alt. Source) 1948	Est. Decade Built
Total Area (square ft) 50000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

Boring Middle School - New Gym

Oregon Trail SD 46

Clac_sch34C

Building Type	County	
School	Clackamas	
Street		
27801 Se Dee St		
City	State	Zip
Boring	OR	97009
Latitude	Longitude	
45.43218	122.37727	
Tracking Code	Inspection Date	
Previous FEMA-154 Report	9/15/2006	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5						
Secondary										
Tertiary										

Boring Middle School - New Gym

Final RVS Score

Final Type	Final Score
RM1	1.3

FEMA-154 Collapse Potential

Moderate (>1%)

Boring Middle School - New Gym

Clac_sch34C

Enrollment 404	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built
Total Area (square ft) 10000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	