

# Sandy Grade School

Oregon Trail SD 46

Clac\_sch36A

Building Type	County
School	Clackamas
Street	
38955 Pleasant St	
City	State Zip
Sandy	OR 97055
Latitude	Longitude
45.39827	122.26257
Tracking Code	Inspection Date
Hasenberg 02	9/15/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	-0.2	0	-0.8	0	0	3.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sandy Grade School

## Final RVS Score

Final Type	Final Score
W2	3.8

## FEMA-154 Collapse Potential

Low (<1%)

# Sandy Grade School

Clac\_sch36A

Enrollment 354	Year Built (Field Verified) 1930	Year Built (Alt. Source) 1930	Est. Decade Built
Total Area (square ft) 42122	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site		
			
S	General Site	S	General Site
			
S	General Site		
			
S	General Site		



# OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries