

Firwood Elementary School

Oregon Trail SD 46

Clac_sch37A

Building Type School	County Clackamas	
Street 42900 Se Trubel Rd		
City Sandy	State OR	Zip 97055
Latitude 45.37376	Longitude 122.22178	
Tracking Code Hasenberg 02	Inspection Date 9/15/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	0	-0.8	0	0	4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Firwood Elementary School

Final RVS Score

Final Type	Final Score
W2	4

FEMA-154 Collapse Potential

Low (<1%)

Firwood Elementary School

Clac_sch37A

Enrollment 466	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built
Total Area (square ft) 46980	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S General Site		S General Site	
		S General Site	
			
S General Site		S General Site	
		S General Site	
		S General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries