

Beavercreek Elementary School

Oregon City SD 62

Clac_sch41A

Building Type	County	
School	Clackamas	
Street		
21944 S Yeoman Rd		
City	State	Zip
Beavercreek	OR	97004
Latitude	Longitude	
45.28852	122.51703	
Tracking Code	Inspection Date	
Hasenberg 02	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Beavercreek Elementary School

Final RVS Score

Final Type

Final Score

RM1

2.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Beavercreek Elementary School

Clac_sch41A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
511		1948	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
47750	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site