

King Elementary School

Oregon City SD 62

Clac_sch46A

Building Type School	County Clackamas	
Street 995 S End Rd		
City Oregon City	State OR	Zip 97045
Latitude 45.33891	Longitude 122.62123	
Tracking Code RVS in 2006	Inspection Date 12/28/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9

King Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

King Elementary School

Clac_sch46A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
411	1959	1958	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
44220	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: U shaped		Steps in Elevation View: 2 to 3 Changes	
Reentrant Corners: Other (Adjacent Build/Entity)		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		None	
Falling Hazards		Poor Conditions	
Other: Ornamental Hazard Over Exit		None	
None		None	
None		None	
			
S Field Verified Year Built	S Seismic Upgrade	SW Plan Irregularity Secondary	
			
S Primary Structural Type	SW Secondary Structural Type	NW Vertical Irregularity Secondary	
			
NE General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

King Elementary School

Oregon City SD 62

Clac_sch46B

Building Type School	County Clackamas	
Street 995 S End Rd		
City Oregon City	State OR	Zip 97045
Latitude 45.33898	Longitude 122.62026	
Tracking Code RVS in 2006	Inspection Date 12/28/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0

King Elementary School

Final RVS Score

Final Type	Final Score
W2	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

King Elementary School

Clac_sch46B

Enrollment 411	Year Built (Field Verified) 1958	Year Built (Alt. Source) 1958	Est. Decade Built 1970
Total Area (square ft) 44220	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 NW Vertical Irregularity Primary		 W Plan Irregularity Secondary	 SE Plan Irregularity Secondary