

Rural Dell Elementary School

Clac_sch57A

Molalla River SD 35

Building Type		County	
School		Clackamas	
Street			
10500 S Hwy 211			
City	State	Zip	
Molalla	OR	97038	
Latitude		Longitude	
45.14832		122.65108	
Tracking Code		Inspection Date	
Hasenberg 02		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	-1	0	0	-0.8	0	2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Rural Dell Elementary School

Final RVS Score

Final Type

Final Score

W2

2

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Rural Dell Elementary School

Clac_sch57A

Enrollment 233	Year Built (Field Verified) 	Year Built (Alt. Source) 1938	Est. Decade Built
Total Area (square ft) 29848	Number of Stories 1	Basement No	Pounding Potential No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site



S General Site

