

Eagle Creek Elementary School

Estacada SD 108

Clac_sch58A

Building Type	County	
School	Clackamas	
Street		
30391 Se Hwy 211		
City	State	Zip
Eagle Creek	OR	97022
Latitude	Longitude	
45.36165	122.35264	
Tracking Code	Inspection Date	
Hasenberg 02	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	0	-0.8	0	3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Eagle Creek Elementary School

Final RVS Score

Final Type

Final Score

W2

3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Eagle Creek Elementary School

Clac_sch58A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
381		1970	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
52570	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions

