

Palisades Elementary School

Lake Oswego SD 7J

Clac_sch69A

Building Type	County	
School	Clackamas	
Street		
1500 Greentree Ave		
City	State	Zip
Lake Oswego	OR	97034
Latitude	Longitude	
45.40178	122.6918	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Palisades Elementary School

Final RVS Score

Final Type	Final Score
W2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)

Palisades Elementary School

Clac_sch69A

Enrollment 353	Year Built (Field Verified) 1959	Year Built (Alt. Source) 1959	Est. Decade Built
Total Area (square ft) 42846	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	