

Oak Creek Elementary School

Clac_sch74A

Lake Oswego SD 7J

Building Type		County	
School		Clackamas	
Street			
55 Kingsgate Rd			
City	State	Zip	
Lake Oswego	OR	97035	
Latitude		Longitude	
45.42716		122.72949	
Tracking Code		Inspection Date	
Structural Engineering Report		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S2	3	-1.5	-0.5	0	0	-0.4	0	0	0.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Oak Creek Elementary School

Final RVS Score

Final Type

Final Score

S2

0.6

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
389		1991	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
57700	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions