

Naas Elementary School

Oregon Trail SD 46

Clac_sch89A

Building Type	County
School	Clackamas
Street	
12240 Se School Ave	
City	State Zip
Boring	OR 97009
Latitude	Longitude
45.43425	122.37848
Tracking Code	Inspection Date
Hasenberg 02	9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	0	0	0	3.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Naas Elementary School

Final RVS Score

Final Type	Final Score
W2	3.8

FEMA-154 Collapse Potential

Low (<1%)

Naas Elementary School

Clac_sch89A

Enrollment 237	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built
Total Area (square ft) 44936	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site		