

Inza R Wood Middle School

West Linn-Wilsonville SD 3J

Clac_sch92A

Building Type		County	
School		Clackamas	
Street			
11055 Sw Wilsonville Rd			
City	State	Zip	
Wilsonville	OR	97070	
Latitude		Longitude	
45.30174		122.79297	
Tracking Code		Inspection Date	
RVS in 2006		12/29/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	-0.4	0	0	3.3
Secondary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0

Inza R Wood Middle School

Final RVS Score

Final Type

Final Score

RM1

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
619	1980	1980	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
77210	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
Other: Brick Veneer	None
None	None
None	None



E Field Verified Year Built
1980



E Falling Hazard



NE Plan Irregularity Secondary
2003 on rt



NE Plan Irregularity Secondary
2003 on rt



NW Plan Irregularity Secondary
2003 on left



W Vertical Irregularity Secondary
high part 2003



SW Vertical Irregularity Secondary
gym on rt



S Vertical Irregularity Secondary
note free-standing brick wall - 12" thick



West Linn-Wilsonville SD 3J

Clac sch92B

Inza R Wood Middle School


Final RVS Score

Final Type	Final Score
------------	-------------

C2

0.9

High (>10%)



Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
619		1980	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
77210	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None
None	None

Falling Hazards	Poor Conditions
Other: Brick Veneer	None
None	None
None	None



S Primary Structural Type
p.i.p. conc



SW Elevation View



SW Primary Structural Type
p.i.p. conc



SE Primary Structural Type
p.i.p. conc

