

Building Type Community_College	County Clatsop	
Street 1653 Jerome Ave		
City Astoria	State OR	Zip 97103
Latitude 46.18356	Longitude 123.82385	
Tracking Code Miller 2004-05	Inspection Date 3/1/2007	

No Photo Available

Seismicity Zone: Very High										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S4	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Badollet Library	
Final RVS Score	
Final Type	Final Score
S4	1.3
FEMA-154 Collapse Potential	
Moderate (>1%)	

**No
Planview
Available**



Badollet Library

Clat_coc02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1965	1965	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
17900	3	Yes	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
Other: Light Cladding			
None			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries