

Building Type Community_College	County Clatsop	
Street 1653 Jerome Ave		
City Astoria	State OR	Zip 97103
Latitude 46.18283	Longitude 123.82397	
Tracking Code Miller 2004-05	Inspection Date 3/1/2007	

No Photo Available

Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0		0	0	2.1
Secondary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Tertiary		0	0	0	0	0	0	0	0	0

Fertig Hall

Final RVS Score

Final Type

Final Score

RM1

1.3

FEMA-154 Collapse Potential

Moderate (>1%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1965	1965	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
17032	1	No	No

Plan Irregularities	Vertical Irregularities
None	Yes: Unknown

Falling Hazards	Poor Conditions
None	
None	

