

Clatsop CC

Building Type Community_College	County Clatsop	
Street 1653 Jerome Ave		
City Astoria	State OR	Zip 97103
Latitude 46.18379	Longitude 123.82465	
Tracking Code Miller 2004-05	Inspection Date 3/1/2007	

No Photo Available

Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	0	0	0	0.3
Secondary	C1	2.5	-1.5	-0.5	-1.2	0	0	0	0	-0.7
Tertiary	PC2	2.4	-1	-0.5	-0.8	0	0	0	0	0.1

Patriot/Towler Hall

Final RVS Score

Final Type	Final Score
C1	-0.7

FEMA-154 Collapse Potential

Very High (100%)

**No
Planview
Available**



Oregon Geology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1940	1940	1900
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
75416	3	Yes	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
Unreinforced Chimneys			
Other: Light Cladding			

