

# Gearhart VFD

City of Gearhart

Clat\_fir04A

Building Type Fire - City	County Clatsop	
Street 670 Pacific Way		
City Gearhart	State OR	Zip 97138
Latitude 46.0244	Longitude 123.91943	
Tracking Code RVS in 2006	Inspection Date 9/13/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	-0.4	0	0	1.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Gearhart VFD

## Final RVS Score

Final Type	Final Score
RM1	1.9

## FEMA-154 Collapse Potential

Moderate (>1%)



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Gearhart VFD

Clat\_fir04A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1958	1958	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE Elevation View		E Primary Structural Type	
		E Elevation View	
			
N Elevation View		NW Elevation View	
		SW Elevation View	
			
S Field Verified Year Built		1958	



# OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries