

# Lewis & Clark RFPD

Lewis & Clark RFPD

Clat\_fir08A

Building Type Fire - RFPD	County Clatsop	
Street 34571 Hwy 105		
City Astoria	State OR	Zip 97103
Latitude 46.15234	Longitude 123.85324	
Tracking Code RVS in 2006	Inspection Date 9/11/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lewis & Clark RFPD

## Final RVS Score

Final Type	Final Score
C2	1.7

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: General		Cracks	
None		None	
None		None	
			
S	Elevation View	SW	Elevation View
		W Poor Condition	
			
NW	Elevation View	W	Elevation View



# Lewis & Clark RFPD

Lewis & Clark RFPD

Clat\_fir08B

Building Type Fire - RFPD	County Clatsop	
Street 34571 Hwy 105		
City Astoria	State OR	Zip 97103
Latitude 46.1525	Longitude 123.8531	
Tracking Code RVS in 2006	Inspection Date 9/11/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	-0.5	0	2.4	0	0	0	6.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lewis & Clark RFPD

Final RVS Score

Final Type  
W1

Final Score  
6.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S Elevation View	SE Elevation View	SW Primary Structural Type	

