

John Day RFPD

Clat_fir10A

John Day RFPD

Building Type		County	
Fire - RFPD		Clatsop	
Street			
38885 Hwy 30			
City	State	Zip	
Astoria	OR	97103	
Latitude		Longitude	
46.16611		123.74873	
Tracking Code		Inspection Date	
RVS in 2006		9/19/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	0	-0.4	0	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John Day RFPD

Final RVS Score

Final Type

Final Score

W2

2.9

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Building Name



SE Primary Structural Type



SE Elevation View



SW Elevation View