

Gearhart City Police Dept

City of Gearhart

Clat_pol02A

Building Type		County	
Police - City		Clatsop	
Street			
698 Pacific Way			
City	State	Zip	
Gearhart	OR	97138	
Latitude		Longitude	
46.02442		123.91893	
Tracking Code		Inspection Date	
RVS in 2006		9/13/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	0	0	0	0	4.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Gearhart City Police Dept

Final RVS Score

Final Type

Final Score

W1

4.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SE Building Name



NW Elevation View



NW Primary Structural Type

