

Cannon Beach Police Dept

City of Cannon Beach

Clat_pol03A

Building Type Police - City	County Clatsop	
Street 163 E Gower St		
City Cannon Beach	State OR	Zip 97110
Latitude 45.88973	Longitude 123.96079	
Tracking Code RVS in 2006	Inspection Date 9/18/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	-1	0	0	0	0	2.3
Secondary	URM	1.8	0	-0.5	-0.2	0	0	0	0	1.1
Tertiary		0	0	0	0	0	0	0	0	0

Cannon Beach Police Dept

Final RVS Score

Final Type	Final Score
URM	1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Cannon Beach Police Dept

Clat_pol03A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1930
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: U shaped		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E	Plan Irregularity Primary	NW	Primary Structural Type
			
E	Elevation View	NW	Elevation View
			
NW	Secondary Structural Type	NW	Elevation View
			
S	Elevation View		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries