

Building Type		County	
Police - State		Clatsop	
Street			
13 Portway			
City		State	Zip
Astoria		OR	97103
Latitude		Longitude	
46.18675		123.85629	
Tracking Code		Inspection Date	
RVS in 2006		9/12/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	0	0	0	0	4.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

OSP

Final RVS Score

Final Type

Final Score

W1

4.4

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Elevation View



N Elevation View



Building Type		County	
Police - State		Clatsop	
Street			
13 Portway			
City		State	Zip
Astoria		OR	97103
Latitude		Longitude	
46.18655		123.85644	
Tracking Code		Inspection Date	
RVS in 2006		9/12/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	-0.4	0	0	3.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

OSP

Final RVS Score

Final Type

Final Score

W2

3.4

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None




W Elevation View



N Elevation View



NW Other



NE Elevation View