

Warrenton High School

Warrenton-Hammond SD 30

Clat_sch09A

Building Type	County	
School	Clatsop	
Street		
1700 SE Main Ave		
City	State	Zip
Warrenton	OR	97146
Latitude	Longitude	
46.14747	123.92828	
Tracking Code	Inspection Date	
RVS in 2006	9/11/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Warrenton High School

Final RVS Score

Final Type	Final Score
C2	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Warrenton High School

Clat_sch09A

Enrollment 259	Year Built (Field Verified) 1945	Year Built (Alt. Source) 1945	Est. Decade Built 1940
Total Area (square ft) 35000	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 NW Elevation View		 W Other	
 SW Elevation View		 W Plan Irregularity Primary	
 W Primary Structural Type		 SW Primary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Warrenton High School

Warrenton-Hammond SD 30

Clat_sch09B

Building Type School	County Clatsop	
Street 1700 SE Main Ave		
City Warrenton	State OR	Zip 97146
Latitude 46.14695	Longitude 123.92821	
Tracking Code RVS in 2006	Inspection Date 9/11/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Warrenton High School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Warrenton High School

Clat_sch09B

Enrollment 259	Year Built (Field Verified) 1945	Year Built (Alt. Source) 1945	Est. Decade Built 1960
Total Area (square ft) 35000	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Reentrant Corners: Other (Adjacent Build/Entity)		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
None		None	
Falling Hazards		Poor Conditions	
Other: Brick Veneer		None	
None		None	
None		None	
			
SW Elevation View		S Vertical Irregularity Primary	
		E Primary Structural Type	
			
SE Elevation View		E Elevation View	
		NE Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Warrenton High School

Warrenton-Hammond SD 30

Clat_sch09C

Building Type	County
School	Clatsop
Street	
1700 SE Main Ave	
City	State Zip
Warrenton	OR 97146
Latitude	Longitude
46.14732	123.9279
Tracking Code	Inspection Date
RVS in 2006	9/11/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Warrenton High School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Warrenton High School

Clat_sch09C

Enrollment 259	Year Built (Field Verified) 1945	Year Built (Alt. Source) 1945	Est. Decade Built 1960
Total Area (square ft) 35000	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
 SW Elevation View		 SW Elevation View	
		 NW Vertical Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries