

Clatskanie Rural Fire

Clatskanie RFPD

Colu_fir10A

Building Type		County	
Fire - RFPD		Columbia	
Street			
280 Se 3rd St			
City	State	Zip	
Clatskanie	OR	97016	
Latitude		Longitude	
46.10227		123.20249	
Tracking Code		Inspection Date	
RVS in 2006		9/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clatskanie Rural Fire

Final RVS Score

Final Type

Final Score

W2

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Clatskanie Rural Fire

Colu_fir10A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1970	1970	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
None	None
None	None

Falling Hazards	Poor Conditions
Other: General	None
None	None
None	None



SE Building Name



SE Elevation View



SW Vertical Irregularity Primary



W Plan Irregularity Primary



NE Elevation View