

Building Type		County	
Fire - RFPD		Columbia	
Street			
555 E Bridge St			
City	State	Zip	
Vernonia	OR	97064	
Latitude		Longitude	
45.85738		123.18032	
Tracking Code		Inspection Date	
RVS in 2006		9/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	0	0	0	-0.4	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Vernonia RFPD

Final RVS Score

Final Type

Final Score

S3

2.8

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No

Plan Irregularities	Vertical Irregularities
None	Internal Discontinuous Diaphragm (large internal opening)
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SW Elevation View



SE Elevation View



NW Primary Structural Type