

Clatskanie Police Dept

City of Clatskanie

Colu_pol05A

Building Type		County	
Police - City		Columbia	
Street			
195 Se 2nd St			
City	State	Zip	
Clatskanie	OR	97016	
Latitude		Longitude	
46.10322		123.20433	
Tracking Code		Inspection Date	
RVS in 2006		9/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	0	0	2.4	0	0	0	4.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clatskanie Police Dept

Final RVS Score

Final Type

Final Score

W1

4.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	Yes	No

Plan Irregularities	Vertical Irregularities
None	Building On Hill or Sloped Site
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



NW Elevation View