

Clatskanie Elementary School

Clatskanie SD 6J

Colu_sch02A

Building Type School	County Columbia	
Street 815 S Nehalem St		
City Clatskanie	State OR	Zip 97016
Latitude 46.09905	Longitude 123.20696	
Tracking Code RVS in 2006	Inspection Date 9/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	-0.4	0	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clatskanie Elementary School

Final RVS Score

Final Type	Final Score
W2	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Clatskanie Elementary School

Colu_sch02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
388	1927	1927	1920
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
49008	2	No	Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:Other (Adjacent Build/Entity)		Building On Hill or Sloped Site	
Out of Plane Lateral-Force-Resistance Elements		Steps in Elevation View: 2 to 3 Changes	
None		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE Plan Irregularity Primary conn to new bldg		S General Site new bldg	
		N Vertical Irregularity Tertiary	
			
N Vertical Irregularity Primary		NW Elevation View	
		W Building Name	
			
W Building Name		W Seismic Upgrade	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Clatskanie Elementary School

Clatskanie SD 6J

Colu_sch02B

Building Type School	County Columbia	
Street 815 S Nehalem St		
City Clatskanie	State OR	Zip 97016
Latitude 46.0994	Longitude 123.20622	
Tracking Code RVS in 2006	Inspection Date 9/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	0	-0.4	0	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clatskanie Elementary School

Final RVS Score

Final Type	Final Score
W2	2.9

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Clatskanie Elementary School

Colu_sch02B

Enrollment 388	Year Built (Field Verified) 1927	Year Built (Alt. Source) 1927	Est. Decade Built 1960
Total Area (square ft) 49008	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
S Plan Irregularity Primary		SE Elevation View	
			
NE Elevation View		NW Plan Irregularity Primary	
			
NW Falling Hazard		SE Falling Hazard	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries