

Hudson Park Elementary School

Rainier SD 13

Colu sch04A

Building Type	County	
School	Columbia	
Street		
28176 Old Rainier Rd		
City	State	Zip
Rainier	OR	97048
Latitude	Longitude	
46.09155	122.98908	
Tracking Code	Inspection Date	
RVS in 2006	9/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

Hudson Park Elementary School

Final RVS Score

Final Type

Final Score

C2

0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hudson Park Elementary School

Colu_sch04A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
598	1978	1978	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
35992	2	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
W Plan Irregularity Primary	S Vertical Irregularity Primary	SE Elevation View	
SE Plan Irregularity Primary	N Number of Stories		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hudson Park Elementary School

Rainier SD 13

Colu_sch04B

Building Type School	County Columbia	
Street 28176 Old Rainier Rd		
City Rainier	State OR	Zip 97048
Latitude 46.09124	Longitude 122.98974	
Tracking Code RVS in 2006	Inspection Date 9/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	0	0	0	0	-0.6	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hudson Park Elementary School

Final RVS Score

Final Type	Final Score
C2	2.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Hudson Park Elementary School

Colu_sch04B

Enrollment 598	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1970
Total Area (square ft) 35992	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
N General Site		NE Elevation View	
		S Elevation View	
		E Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hudson Park Elementary School

Rainier SD 13

Colu_sch04C

Building Type	County	
School	Columbia	
Street		
28176 Old Rainier Rd		
City	State	Zip
Rainier	OR	97048
Latitude	Longitude	
46.09222	122.98984	
Tracking Code	Inspection Date	
RVS in 2006	9/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hudson Park Elementary School

Final RVS Score

Final Type	Final Score
C2	0.7

FEMA-154 Collapse Potential

High (>10%)



Hudson Park Elementary School

Colu_sch04C

Enrollment 598	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1970
Total Area (square ft) 35992	Number of Stories 2	Basement	Pounding Potential Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Reentrant Corners: Other (Adjacent Build/Entity)		Building On Hill or Sloped Site	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Vertical Irregularity Secondary		W Number of Stories	
		SW Primary Structural Type FORM TIE MARKS	
			
SW Plan Irregularity Primary		SW Vertical Irregularity Secondary	
		SE Plan Irregularity Primary	
			
SW General Site conn to a		E Vertical Irregularity Primary	
		NE General Site conn to a	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hudson Park Elementary School

Colu_sch04C



E Vertical Irregularity Primary



E Pounding Potential



E Elevation View