

# Washington Elementary School

Vernonia SD 47J

Colu\_sch05A

Building Type	County
School	Columbia
Street	
199 Bridge St	
City	State Zip
Vernonia	OR 97064
Latitude	Longitude
45.85837	123.18681
Tracking Code	Inspection Date
Structural Engineering Report	9/15/2006



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	-0.4	0	0	-0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Washington Elementary School

### Final RVS Score

Final Type	Final Score
URM	-0.3

### FEMA-154 Collapse Potential

Very High (100%)

# Washington Elementary School

Colu\_sch05A

Enrollment 296	Year Built (Field Verified) 1930	Year Built (Alt. Source) 1930	Est. Decade Built
Total Area (square ft) 56068	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



S General Site



S General Site



S General Site



S General Site



S General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries