

Rainier Jr/Sr High School

Rainier SD 13

Colu_sch10A

Building Type School	County Columbia	
Street 28170 Old Rainier Rd		
City Rainier	State OR	Zip 97048
Latitude 46.09176	Longitude 122.98833	
Tracking Code RVS in 2006	Inspection Date 9/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Rainier Jr/Sr High School

Final RVS Score

Final Type	Final Score
C2	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Rainier Jr/Sr High School

Colu_sch10A

Enrollment 589	Year Built (Field Verified) 1976	Year Built (Alt. Source) 1976	Est. Decade Built 1970
Total Area (square ft) 136887	Number of Stories 2	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Building On Hill or Sloped Site None	
Falling Hazards None None None		Poor Conditions None None None	
			
S Vertical Irregularity Primary		S Primary Structural Type	
		S Vertical Irregularity Secondary	
			
SE General Site		E Plan Irregularity Primary	
		E Vertical Irregularity Primary	
			
N Elevation View		N Plan Irregularity Primary	
		NW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries



NW Pounding Potential



Rainier Jr/Sr High School

Rainier SD 13

Colu_sch10B

Building Type School	County Columbia	
Street 28170 Old Rainier Rd		
City Rainier	State OR	Zip 97048
Latitude 46.09115	Longitude 122.98825	
Tracking Code RVS in 2006	Inspection Date 9/1/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Rainier Jr/Sr High School

Final RVS Score

Final Type	Final Score
C2	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Rainier Jr/Sr High School

Colu_sch10B

Enrollment 589	Year Built (Field Verified) 1976	Year Built (Alt. Source) 1976	Est. Decade Built 1970
Total Area (square ft) 136887	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
NW Plan Irregularity Primary		NE Plan Irregularity Primary	E Elevation View



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries