

Vernonia High School

Vernonia SD 47J

Colu_sch13A

Building Type School	County Columbia	
Street 299 Bridge St		
City Vernonia	State OR	Zip 97064
Latitude 45.85833	Longitude 123.18953	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Vernonia High School

Final RVS Score

Final Type	Final Score
W2	0.9

FEMA-154 Collapse Potential

High (>10%)

Vernonia High School

Colu_sch13A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
241		1950	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
42670	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions



S General Site



S General Site



S General Site



S General Site



S General Site