

Coaledo Hall

Southwest Oregon CC

Coos_coc01A

Building Type		County	
Community_College		Coos	
Street			
1988 Newmark Ave			
City	State	Zip	
Coos Bay	OR	97420	
Latitude	Longitude		
43.39535	124.25223		
Tracking Code	Inspection Date		
Miller 2004-05	7/14/2005		

No Photo Available

Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Coaledo Hall

Final RVS Score

Final Type


Final Score

C2

0.7

FEMA-154 Collapse Potential

High (>10%)



Directory by Building

- | | |
|-----------------------------------|--------------------------------|
| 1. DELLWOOD HALL | 23. OFFICES |
| 2. STENSLAND | 24. SOCCER FIELD |
| 3. RANDOLPH HALL | 25. GUARD SHACK |
| 4. EMPIRE HALL/ PERF. ARTS CENTER | 26. PLANT SERVICES / MAINT. |
| 5. TIOGA HALL | 27. FAMILY CENTER / CHILD CARE |
| 6. SITKUM HALL | 28. NEWMARK CENTER |
| 7. COALEDO HALL | 29. NORTH HEAD |
| 8. EDEN HALL | 30. LIGHTHOUSE DEPOT |
| 9. LAMPA HALL | 31. ST. GEORGE REEF |
| 10. B-2 | 32. CAPE BLANCO |
| 11. SUNSET HALL | 33. COQUILLE RIVER |
| 12. SUMNER HALL | 34. CAPE ARAGO |
| 13. FAIRVIEW HALL | 35. UMPQUA RIVER |
| 14. TENNIS COURTS | 36. HECETA HEAD |
| 15. FIELD HOUSE | 37. YAQUINA HEAD |
| 16. FIRE SCIENCE | 38. CAPE MEARES |
| 17. BASEBALL FIELD | 39. TILLAMOOK ROCK |
| 18. FIRE TOWER | 40. POINT ADAMS |
| 19. SOFTBALL FIELD | 41. DESDEMONA SANDS |
| 20. PROSPER HALL | 42. WARRIOR ROCK |
| 21. UMPQUA HALL | 43. WILLAMETTE RIVER |
| 22. B-3 STORAGE | 44. VOLLEYBALL COURT |
| | 45. BASKETBALL COURT |

Directory by Code

- | | |
|------------------------|---------------------|
| STEN- Stensland | EMPH- Empire Hall |
| NEW- Newmark Center | RAND- Randolph Hall |
| SITK- Sitkum Hall | TIOG- Tioga Hall |
| SUMN- Sumner Hall | UMPQ- Umpqua Hall |
| EDEN- Eden | FLD- Field |
| COAL- Coaledo | B3- B3 Storage |
| PROS- Prosper Hall Gym | SUNS- Sunset Hall |
| FAIR- Fairview Hall | |



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1965	1965	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
9800	2	No	No

Plan Irregularities	Vertical Irregularities
None	None

Falling Hazards	Poor Conditions
None	
None	
None	

